



PIPE SIZE	11 1/4 BEND				22 1/2° BEND				45 ° BEND				90° BEND			
	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D
4"	6"	1'-0"	4"	6"	8"	1'-0"	6"	7"	1'-1"	1'-0"	6"	6"	1'-10"	1'-0"	6"	1'-0"
6"	8"	1'-2"	6"	7"	10"	1'-2"	6"	8"	1'-4"	1'-2"	6"	8"	2'-3"	1'-2"	6"	1'-6"
8"	8"	1'-4"	8"	7"	1'-4"	1'-4"	8"	8"	2'-0"	1'-4"	8"	9"	3'-3"	1'-4"	8"	1'-6"
10"	1'-1"	1'-6"	8"	8"	1'-7"	1'-6"	8"	10"	2'-6"	1'-6"	8"	10"	3'-9"	2'-0"	10"	1'-6"
12"	1'-4"	1'-8"	1'-0"	9"	2'-0"	1'-8"	1'-0"	1'-0"	3'-3"	1'-8"	1'-0"	1'-0"	5'-0"	2'-0"	10"	1'-6"
16"	1'-9"	2'-0"	1'-0"	9"	2'-6"	2'-0"	1'-0"	1'-3"	4'-3"	2'-6"	1'-0"	1'-3"	6'-0"	2'-6"	1'-4"	1'-9"
18"	1'-9"	2'-6"	1'-0"	10"	3'-3"	2'-6"	1'-0"	1'-6"	6'-0"	2'-6"	1'-0"	1'-4"	8'-0"	3'-4"	1'-8"	1'-9"
20"	1'-9"	2'-6"	1'-0"	10"	3'-3"	2'-6"	1'-0"	1'-6"	6'-0"	2'-6"	1'-0"	1'-4"	8'-0"	3'-4"	1'-8"	1'-9"
24"	2'-0"	3'-0"	1'-0"	1'-0"	3'-9"	3'-0"	1'-0"	1'-6"	7'-0"	3'-0"	1'-0"	1'-9"	9'-9"	4'-0"	2'-0"	2'-0"

NOTE:

- 1.) BLOCKING DIMENSIONS ARE SHOWN AT A MINIMUM.
- 2.) BLOCKING DIMENSIONS ARE BASED ON A STATIC PRESSURE OF 150 PSI AND AN ALLOWABLE SOIL BEARING CAPACITY OF 2000 PSF.
- 3.) WHERE SOIL BEARING CAPACITY IS LESS THAN OR GREATER THAN 2000 PSF, BLOCKING DESIGN CALCULATION ARE TO BE SHOWN ON THE PLANS.
- 4.) FITTINGS TO BE WRAP IN 4 MIL POLYETHYLENE TO PROTECT NUTS, BOLTS, OR OTHER.
- 5.) CONCRETE TO BE 3000 PSI.